



## BACKGROUND

The City of Toronto chose to install a 3.2 kW photovoltaic system at Fire Hall 334 to evaluate the performance of the technology and to showcase the City's environmental leadership. Installed in December 2006, the project is taking advantage of the Ontario Power Authority's micro Feed-in Tariff program.

## MONITORING

Installed on site is a Fronius Data Acquisition System. Monitored parameters include solar irradiance, cell and ambient temperature, wind speed, and energy output by the inverter.



## FINANCIAL

The project was entirely by City of Toronto from the Capital Budget. The system will pay for itself in approximately 20 years and continue generating electricity for years after.

## STATUS

FIT payments began in July 2010 and should provide a reliable revenue stream for the City of Toronto for the next 20 years.

## For more information, contact:

Joel Arthurs, Energy Management Analyst, Energy and Waste Management Office, City of Toronto  
416-392-5177; [jarthurs@toronto.ca](mailto:jarthurs@toronto.ca)

# Fire Station #334

## 3.2 kW Photovoltaic System



### Project Overview

Project Owner: City of Toronto  
Location: 339 Queen's Quay West, Toronto, ON  
Building type and use: Fire Station  
System type: Grid connected PV  
System power rating: 3.2 kW  
Installation date: December 2006

### System Configuration

System Surface Area: 19 m<sup>2</sup>  
Total number of Modules: 16  
Module Manufacturer: Sanyo  
Module Wattage: 200 W  
Module Model: HIP-200BA3  
Inverter Manufacturer: Fronius  
Inverter Model: IG 4500-LV (4.5 kW)  
Number of Inverters: 1  
Array Angle: 25 degrees from horizontal  
Azimuth: 15 degrees West of South  
String Configuration: 4 modules per string, 4 parallel strings

### Annual Performance

3 year average actual performance: 1,210 kWh/kW

### Financial

System Cost (including tax): \$62,007  
Grants: None  
Annual Income: \$3,106\*  
Cost per kW: \$19,377  
Simple Payback: 19.7 years

### Environmental Benefits

Estimated emission reduction: 0.724 tonnes CO<sub>2</sub>e /yr\*\*

\*based on FIT rate of 71.3 ¢/kWh

\*\*based on 0.187 kg CO<sub>2</sub>e/kWh

© 2012, [City of Toronto, Toronto Atmospheric Fund, Toronto and Region Conservation Authority]. All Rights Reserved.

This feasibility study was carried out with assistance from the Green Municipal Fund, a Fund financed by the Government of Canada and administered by the Federation of Canadian Municipalities. Notwithstanding this support, the views expressed are the personal views of the authors, and the Federation of Canadian Municipalities and the Government of Canada accept no responsibility for them.