



BACKGROUND

The City of Toronto chose to install a 50 kW_t solar pool heating system at the Weston Lions outdoor pool to collect heat from the sun and deliver it to the swimming pool. Designed to reduce the need for a conventional natural gas pool heating system, the system will function during the Spring, Summer and Fall when there is no risk of freezing.

FINANCIAL

Fifty percent of the project was funded by the City with a remaining 25% coming from Natural Resources Canada's ecoENERGY for Renewable Heat program and 25% coming from Ontario's Solar Thermal Heating Incentive program.

PERFORMANCE

The performance of the installed equipment was hampered by multiple data collection and operational issues. These included: closures due to municipal strike in 2009; improper monitoring equipment set up; unwanted operation during times when solar production was low (ie overnight) which produced cooling effects for the pools; equipment damage; loss of data due to lack of integration with central data collection systems; and unwarranted shut-downs due to site-operator error.

Despite the many challenges associated with these installations, some key lessons were clearly established including: the **importance of sensor placements and set points** – affecting times at which the pool is programmed to access the thermal heating – to the ability of the pool to make full use of available solar energy; the **susceptibility of solar pool heating systems to add unwanted cooling** to the pool due to inadequate check-valve systems; and the need to **ensure that on-site pool staff are engaged** and have a basic understanding of the system and the skills to do ensure that it is functioning throughout the pool season.

Please see the *Performance Review of Public Outdoor Pool Solar Thermal Heating Systems in the City of Toronto* for more in depth analysis.

For more information, contact:

Joel Arthurs, Energy Management Analyst, Energy and Waste Management Office, City of Toronto
416-392-5177; jarthurs@toronto.ca

Weston Lions Outdoor Pool

50 kW_t Solar Pool Heating



Project Overview

Owner: City of Toronto
Address: 2125 Lawrence Avenue West
Building type and use: Outdoor City Pool
System type: Solar Pool Heating
System power rating: 50 kW_t
Installation date: October 2008
Installer: Solar Ontario

System Configuration

System surface area: 71 m²
Collector manufacturer: Techno-Solis
Solar controller: Goldline Aqua SolarTC

Annual Performance

Estimated: 17,724 kWh_t

Financial

System Cost: \$19,562.00
Grants: \$9,781.00
Net System Cost: \$9,781
Cost per kW: \$196
Annual Cost Savings: \$1,300*
Simple Payback: 7.52 years

Environmental Benefits

Estimated emission reduction: 4.7 tonnes eCO₂/yr**

*based on 51 ¢/m³

**based on 1.86 kg eCO₂/m³

© 2012, [City of Toronto, Toronto Atmospheric Fund, Toronto and Region Conservation Authority]. All Rights Reserved.

This feasibility study was carried out with assistance from the Green Municipal Fund, a Fund financed by the Government of Canada and administered by the Federation of Canadian Municipalities. Notwithstanding this support, the views expressed are the personal views of the authors, and the Federation of Canadian Municipalities and the Government of Canada accept no responsibility for them.